# Certificate of Compliance

**Certificate:** 80291916
**Project:** 80291916
**Issued To:** **Anker Solix Innovations Limited**
**Flat/RM 829, 8/F, Tower 2,**
**Admiralty Centre, 18 Harcourt Road,**
**Hong Kong, Hong Kong 999077,**
**China**

**Attention: Wilson Zhu**

**Master Contract:** 306435
**Date Issued:** Feb. 28, 2026

***The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.***

C US

**Issued by:** Hanson Yao

Hanson Yao

**PRODUCTS**

| |
|---|
| CLASS - C531109 - POWER SUPPLIES Distributed Generation Power Systems Equipment |
| CLASS - C531189 - POWER SUPPLIES - Distributed Generation Power Systems Equipment - Certified to U.S. Standards |

| Automatic Transfer Switch Box | |
|---|---|
| Model: | AX170-ATS |
| Notes:<br>For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report. | |


© 2026 CSA Group. All rights reserved.

**Certificate:** 80291916
**Project:** 80291916

**Master Contract:** 306435
**Date Issued:** Feb. 28, 2026

## APPLICABLE REQUIREMENTS

| | | |
|---|---|---|
| CSA C22.2 No. 107.1-16 | - | Power conversion equipment (reaffirmed 2021) |
| UL 1741 | - | Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Third Edition, May 19, 2023) |
| *UL 1741 CRD | - | Power Control Systems (PCS) (issued on April 8, 2023) |
| *UL 3141 | - | Outline of Investigation for Power Control Systems (Issue Number 2, October 9, 2024) |
| *Note:<br>The operating modes evaluated according to UL 1741 PCS CRD & UL 3141 PCS include: Busbar Overload Control (BBOC). | | |

## OTHER REQUIREMENTS

| | | |
|---|---|---|
| UL 67 | - | Panelboards (Thirteenth Edition, Dated May 15, 2018) |
| UL 869A | - | Reference Standard for Service Equipment (Fourth Edition, Dated November 10, 2006) |
| CSA C22.2 No. 29-15 | - | Panelboards and Enclosed panelboards |

Notes:

Products certified under Class C531109 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca


© 2026 CSA Group. All rights reserved.

# *Supplement to Certificate of Compliance*

**Certificate:** 80291916 **Master Contract:** 306435

***The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.***

## Product Certification History

| Project | Date | Description |
|---|---|---|
| 80291916 | Feb. 28, 2026 | (1) Microgrid interconnection device (MID), Model: AX170-ATS, used as Panelboards and/or Service Equipment. Evaluated the device to comply with standards UL 67, UL 869A, and CSA C22.2 No. 29-15, for details refer to project No.: 80291915.<br><br>(2) UL 1741 CRD Power Control Systems (PCS) (issued on April 8, 2023) and UL 3141 Outline of Investigation for Power Control Systems (Issue Number 2, October 9, 2024) were evaluated for controlling Bus bar to comply with UL 67, Clause 6.6.12's requirements.<br><br>(3) UL 1741 (Third Edition, May 19, 2023) and CSA C22.2 No. 107.1-16 (Power conversion equipment, 2021 Edition) are evaluated for the whole device, for details refer to project No.: 80291915.<br><br>WMTC lab assessment. |


© 2026 CSA Group. All rights reserved.